

# Greater Ouachita Water Company North Monroe Water System Lead Copper Rule Materials Inventory

To the best of Greater Ouachita Water System knowledge from repairing and replacing numerous lines in the **North Monroe Water System LA1073035**, the following materials have been found to be in use in the water distribution system:

- A/C
- PVC
- Cast iron
- Copper
- Galvanized iron
- PE Pipe
- Steel

No lead main lines have been observed in the North Monroe Water distribution system.

Types of service lines that have been observed in the North Monroe Water system:

- Copper
- Galvanized iron
- PEX
- PVC

No lead service lines have been observed in the North Monroe Water System.

The following home plumbing materials may be used in the homes of the North Monroe Water System:

- Cast Iron
- Galvanized iron
- Copper
- PEX
- PVC

The following is a summary of the historical lead and copper results in mg/L for the North Monroe Water System LA1073035:

Location	2010 Copper	2010 Lead	2013 Copper	2013 Lead	2016 Copper	2016 Lead
Holland Dr	0.0	0.000	0.0	0.000	0.0	0.000
Holland Dr	0.0	0.000	0.0	0.000	0.0	0.000
Holland Dr	0.0	0.000	0.0	0.000	0.0	0.000
Holland Dr	0.0	0.000	0.0	0.000	0.0	0.000
Holland Dr	0.0	0.000	0.0	0.000	0.0	0.001
Holland Dr	0.0	0.000	0.0	0.000	0.0	0.000
Bayou Bank Dr	0.0	0.001	0.0	0.000	0.0	0.001
Bayou Bank Dr	0.0	0.001	0.0	0.001	0.0	0.000
Pecan Bayou Dr	0.0	0.000	0.0	0.000	0.0	0.001
Pecan Bayou Dr	0.0	0.000	0.0	0.000	0.0	0.000
Pecan Bayou Dr	0.0	0.000	0.0	0.000	0.0	0.000
York Dr	0.0	0.000	0.0	0.000	0.0	0.000
York Dr	0.0	0.000	0.0	0.000	0.0	0.000
York Dr	0.0	0.000	0.0	0.000	0.0	0.000
Dover Place	0.0	0.000	0.0	0.000	0.0	0.000
Dover Place	0.0	0.000	0.0	0.000	0.0	0.000
Finks Hideaway Rd	0.0	0.000	0.0	0.000	0.0	0.000
Barkley Place	0.0	0.000	0.0	0.000	0.0	0.000
Sutton Place	0.0	0.000	0.0	0.000	0.0	0.000
Camelot Place	0.0	0.000	0.0	0.000	0.1	0.000

The action level for lead is 0.015 mg/L. The action level for copper is 1.3 mg/L